

AVA STYL CSI SPECIFICATIONS

SECTION 09 65 19 RESILIENT TILE FLOORING

PART 1. GENERAL

- 1.1 Section includes: Resilient plank tile floor covering and accessories.
- 1.2 Related requirements:
 - 1.2.1 Drawings and General Provisions of the Contract (including General and Supplementary Conditions and Division 1 References Section)
 - 1.2.1.1 Section 03: Concrete (subfloors)
 - 1.2.1.2 Section 06: Wood (subfloors)
- 1.3 REFERENCE STANDARDS
 - 1.3.1 ASTM International
 - 1.3.1.1 D 2047 Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring Surfaces as Measured by the James Machine
 - 1.3.1.2 E 648 Standard Test Method for Critical Radiant Flux of Flooring Systems Using a Radiant Energy Source
 - 1.3.1.3 E 662 Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials
 - 1.3.1.4 F 710 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring
 - 1.3.1.5 F 970 Standard Test Method for Static Load Limit
 - 1.3.1.6 F 1482 Standard Practice for Installation and Preparation of Panel Type Underlayments to Receive Resilient Flooring
 - 1.3.1.7 F 1700 Standard Specification for Vinyl Floor Tile
 - 1.3.1.8 F 2170 Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using In Situ Probes
 - 1.3.1.9 F 2419 Standard Practice for Installation of Thick Poured Gypsum Concrete Underlayments and Preparation of the Surface to Receive Resilient Flooring
- 1.4 OTHER REFERENCED DOCUMENTS, ASSOCIATIONS OR STANDARDS
 - 1.4.1 National Fire Protection Association (NFPA) 253: Standard Test Method for Critical Radiant Flux of Floor Covering Systems Using a Radiant Energy Source
 - 1.4.2 American Concrete Institute
 - 1.4.3 Resilient Floor Covering Institute
 - 1.4.4 American Plywood Association
- 1.5 ADMINISTRATIVE REQUIREMENTS
 - 1.5.1 Coordination: Install floor covering after finishing operations, including painting and ceiling operations, have been completed.



Flooring Solutions Beyond the Expected



- 1.5.2 Preinstallation Meetings: Meet to confirm project requirements, substrate conditions, manufacturer's installation instructions and warranty requirements in compliance with Division 1 requirements.
- 1.5.3 Sequencing: Do not install floor covering over concrete substrates until substrates have cured and are dry to bond with adhesive as determined using test methods specified in ASTM F710 and following adhesive manufacturer's instructions.
- 1.6 SUBMITTALS
 - 1.6.1 General: Submit listed submittals in accordance with Conditions of the Contract and Division 1 Submittal Procedures.
 - 1.6.2 Product Data: For specified products, submit latest edition of product supplier's technical specifications data (available by contacting KRS Inc. at 262.798.8900 or info@krsinc.com).
 - 1.6.3 Samples: Submit selection and verification samples showing the required finishes, colors, designs, and textures for flooring, as well as samples of adhesives and applicable accessories such as underlayment, trim moldings, etc.
 - 1.6.4 Samples for verification of floor covering submit one full tile or plank per pattern, color or SKU.
 - 1.6.5 Test and Evaluation reports as required by Conditions of the Contract and Division 1 Regulatory Requirements Section, submit test certificates from an independent test laboratory showing compliance with specified performance characteristics and physical properties.
 - 1.6.6 Compatibility and adhesion test reports: Submit test reports confirming adhesive's effectiveness with the product(s) specified when adhesive products are not the Resilient Flooring manufacturer's branded products.
 - 1.6.7 Manufacturer Instructions: For specified products, submit latest editions of product supplier's installation and cleaning & maintenance instructions (available by [contacting KRS Inc.](#)).
 - 1.6.8 Warranty documentation: For specified products and accessories, submit product supplier's warranty documents (available by [contacting KRS Inc.](#) at 262.798.8900 or info@krsinc.com).
- 1.7 SUSTAINABILITY REQUIREMENTS
 - 1.7.1 AVA STYL
 - 1.7.1.1 MR Credit – Building Product Disclosure and Optimization
 - 1.7.1.1.1 Environmental Product Declaration, Option 1
 - 1.7.1.1.2 Material Ingredients, Option 1 Health Product Declaration
 - 1.7.1.1.3 Material Ingredients, Option 2 REACH Certification
 - 1.7.1.2 EQ Credit – Low Emitting Materials
 - 1.7.1.2.1 Option 1 FloorScore® Certification (must be used with LEED Compliant adhesives)
 - 1.7.2 AVA STYL Adhesives
 - 1.7.2.1 IEQ Credit 4.1 – Low Emitting Materials
 - 1.7.2.2 IEQ Credit 4.3 – Low VOC ratings, help qualify installations for this credit as part of a flooring system
 - 1.7.2.3 MR Credit 5 – Regional Materials, on jobsites within 500 miles from manufacturing location: Dalton, GA
- 1.8 QUALITY ASSURANCE



Flooring Solutions Beyond the Expected



- 1.8.1 Manufacturer: Manufacturer shall be ISO 9001, ISO 14001 and ISO 18001 certified.
- 1.8.2 Installer: Installer shall have a minimum of five years of proven experience in performing work of this section and in installing vinyl floor covering similar to that required for this project and shall provide a minimum of three references for comparable systems and installations successfully performed by the installer within the last 18 months.
- 1.8.3 Testing Agencies: Agencies shall be independent and qualified or certified to perform any necessary testing, including but not limited to concrete and moisture testing.
- 1.8.4 Concrete Moisture Test: Perform moisture tests according to ASTM F2170, Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using In Situ Probes.
- 1.8.5 A diagram of the area showing the location and results of each test shall be dated and submitted to the architect, general contractor, and/or end user. If test results exceed the floor covering manufacturer's limits, installation shall not commence until results conform to limits.
- 1.8.6 Concrete pH Test: Perform pH tests on concrete. Readings below 7.0 and above 10.0 can adversely affect resilient flooring or adhesives, or both.
- 1.8.7 Surface porosity testing shall be performed on all concrete, gypsum and other surfaces to ensure proper adhesive and installation is achieved. Follow adhesive manufacturer's guidelines for determining surface porosity.
- 1.8.8 Wood substrate: Reference Standard ASTM F1482, for details on wood underlayment requirements and manufacturer's requirements for acceptable wood underlayment panels.
- 1.9 DELIVERY, STORAGE, AND HANDLING
 - 1.9.1 General: Comply with Division 1 Product Requirements Section.
 - 1.9.2 Delivery and Acceptance Requirements: Comply with the product supplier's ordering and lead time requirements to avoid construction delays, and to allow material to acclimatize as required in the specified product's installation instructions. Accept delivery of materials only if they are in unopened, undamaged packaging that bears the name and brand of the manufacturer/product supplier, project identification, and shipping and handling instructions.
 - 1.9.3 Storage and Handling Requirements: Upon receiving floor covering, immediately remove from pallet and lay on a flat surface. Store tile or plank boxes no more than five boxes high. Store material -- including underlayment panels, patching or underlayment compound, floor covering material, adhesive, and welding rods -- in the original packaging (as delivered) in areas that are enclosed and weather tight with the permanent HVAC system set at a temperature of between 65°F and 80°F for a minimum of 48 hours prior to commencement of installation. In addition, comply with storage and handling requirements listed on product packaging, and described in the latest edition of the product's installation instructions (available by contacting KRS INC. at 262.798.8900 or info@krsinc.com).

PART 2. PRODUCTS

- 2.1 Supplier: AVA by Novalis Innovative Flooring; distributed by Capri cork Represented by KRS Inc. email: info@krsinc.com; website: www.krsinc.com.
- 2.2 Substitutions: no substitutions permitted.
[Specifier note: edit this paragraph to suit project requirements. If substitutions are permitted, edit text. Add text to refer to Division 1 Project Requirements (Product Substitutions Procedures) Section.]
- 2.3 Product Options
 - 2.3.1 AVA STYL Planks
 - 2.3.1.1 Classification: ASTM F1700, Class III, Type B

2.3.1.2	Gauge:	2.0 mm																																
2.3.1.3	Wear layer:	0.2 mm (8.0 mil)																																
2.3.1.4	Size:	6" x 36"																																
2.3.1.5	Carton:	36 sq. ft per case																																
2.3.1.6	Edges:	Straight Edge																																
2.3.1.7	Installation Method:	Direct Glue																																
2.3.1.8	Colors:	<table border="0"> <tr><td>CM001</td><td>Contemporary Maple Blonde</td></tr> <tr><td>CM002</td><td>Contemporary Maple Cappuccino</td></tr> <tr><td>CM003</td><td>Contemporary Maple Espresso</td></tr> <tr><td>CM004</td><td>Contemporary Maple Silver</td></tr> <tr><td>WC001</td><td>Washington Cherry</td></tr> <tr><td>OA001</td><td>Ontario Apple</td></tr> <tr><td>BO001</td><td>Baltic Oak White</td></tr> <tr><td>BO002</td><td>Baltic Oak Taupe</td></tr> <tr><td>BO003</td><td>Baltic Oak Suede</td></tr> <tr><td>BO004</td><td>Baltic Oak Tin</td></tr> <tr><td>SA001</td><td>Sawn Oak Brown</td></tr> <tr><td>SA002</td><td>Sawn Oak Grey</td></tr> <tr><td>AW001</td><td>American Walnut Tan</td></tr> <tr><td>AW002</td><td>American Walnut Honey</td></tr> <tr><td>AW003</td><td>American Walnut Cinnamon</td></tr> <tr><td>AW004</td><td>American Walnut Charcoal</td></tr> </table>	CM001	Contemporary Maple Blonde	CM002	Contemporary Maple Cappuccino	CM003	Contemporary Maple Espresso	CM004	Contemporary Maple Silver	WC001	Washington Cherry	OA001	Ontario Apple	BO001	Baltic Oak White	BO002	Baltic Oak Taupe	BO003	Baltic Oak Suede	BO004	Baltic Oak Tin	SA001	Sawn Oak Brown	SA002	Sawn Oak Grey	AW001	American Walnut Tan	AW002	American Walnut Honey	AW003	American Walnut Cinnamon	AW004	American Walnut Charcoal
CM001	Contemporary Maple Blonde																																	
CM002	Contemporary Maple Cappuccino																																	
CM003	Contemporary Maple Espresso																																	
CM004	Contemporary Maple Silver																																	
WC001	Washington Cherry																																	
OA001	Ontario Apple																																	
BO001	Baltic Oak White																																	
BO002	Baltic Oak Taupe																																	
BO003	Baltic Oak Suede																																	
BO004	Baltic Oak Tin																																	
SA001	Sawn Oak Brown																																	
SA002	Sawn Oak Grey																																	
AW001	American Walnut Tan																																	
AW002	American Walnut Honey																																	
AW003	American Walnut Cinnamon																																	
AW004	American Walnut Charcoal																																	

2.3.2 AVA STYL 2G Clic Planks

2.3.2.1	Classification:	ASTM F1700, Class III, Type B
2.3.2.2	Gauge:	3.2 mm
2.3.2.3	Wear layer:	0.2 mm (8.0 mil)
2.3.2.4	Size:	5.74" x 35.74"
2.3.2.5	Carton:	22.79 sq. ft per case
2.3.2.6	Edges:	Straight Edge
2.3.2.7	Installation Method:	2G Clic
2.3.2.8	Colors:	All STYL colors listed in section 2.3.1.8

2.4 Performance: Physical properties of AVA Planks and Tiles shall conform to the published technical specifications for each individual product. Technical data can be obtained by contacting KRS Inc.

2.5 ACCESSORY PRODUCTS

2.5.1 Adhesives:

- 2.5.1.1 Transitional vinyl adhesive Novalis type NFA-T226 (available from Capri) shall be used in full spread applications. Apply adhesive according to manufacturer's recommendations.
- 2.5.1.2 Aerosol spray adhesive from Novalis type NFA-S300 (available from Capri) shall be used in full spread and loose lay applications. Apply adhesive according to manufacturer's recommendations and installation guidelines for the specific flooring.

- 2.5.2 Provide matching trims, moldings and reducing strips specifically designed for luxury vinyl flooring. Architect / Designer shall specify the type and color of each molding. Follow industry or manufacturer's guidelines for proper use and installation of all moldings.
- 2.5.3 Cleaning Products: Architect can specify per the latest edition of the maintenance instructions (available by [contacting KRS Inc.](mailto:info@krsinc.com) at 262.798.8900 or info@krsinc.com).

PART 3. EXECUTION

3.1 EXAMINATION

- 3.1.1 Overall: Follow guidelines laid out in Division 01, Section 01 71 00 – Examination and Preparation as well as Section 01 43 00 – Quality Assurance.
- 3.1.2 Verification of Conditions: Inspect all substrates and subfloors for proper tolerances and dryness, and report any discrepancies to the general contractor in writing.
- 3.1.3 Pre-installation Testing: Verify that concrete testing per ASTM F710 has been conducted by an independent testing agency, and that results are within the adhesive and floor covering manufacturers' requirements.
- 3.1.4 Evaluation and Assessment: See the state requirements for the project location.

3.2 SURFACE PREPARATION

- 3.2.1 Follow guidelines laid out in Division 01, Section 01 71 00 – Examination and Preparation.
- 3.2.2 Prepare concrete substrates per ASTM F 710. All work required to put the concrete subfloor in acceptable condition shall be the responsibility of the general contractor. See the state requirements for the project location.

3.3 INSTALLATION

- 3.3.1 Follow Division 01 relevant guidelines, and the latest edition of the manufacturer's installation instructions (available from www.avafloor.com)
- 3.3.2 Interface with Other Work: If transitions are required to and/or from the specified floor covering, contact the supplier for suitable transition material.

3.4 FIELD QUALITY CONTROL

- 3.4.1 Field Tests: this is for installed work (after job is done)
- 3.4.2 Manufacturer Services: Coordinate with supplier if an on-site manufacturer's representative is desired.

3.5 CLEANING

- 3.5.1 General: Clean up job site, including sweeping or dust mopping the floor to remove all dirt or grit, and put all waste in general contractor's dumpster. Follow overall cleaning guidelines described in Division 01.
- 3.5.2 Initial Maintenance: Conduct a full initial maintenance following the latest edition of the manufacturer's maintenance instructions (available by contacting KRS Inc.)

3.6 CLOSEOUT ACTIVITIES

- 3.6.1 Follow state requirements and Division 01 Section 01 76 00 – Protecting Installed Construction and Section 01 78 00 – Closeout Submittals requirements for these activities.

END OF SECTION